





Model 14, 16, 17, 19	
Dia. X Min. Length Req'd. In Heated Area	
<b>C</b>	 <b>COMBINATION</b> Copper Sweat Fitting 1/2" K, L or M Inside 3/4" M Only Outside 15/16" Dia X 15/16"
<b>C1</b>	 1/2" Copper Sweat Fitting <b>Model 14 ONLY</b> 7/8" Dia X 1/2"
<b>CP</b>	 <b>COMBINATION</b> 1/2" Male Pipe Thread 1/2" Female Sweat 15/16" Dia X 1 1/4"
<b>P</b>	 <b>COMBINATION</b> 1/2" Female Pipe Thread 3/4" Male Pipe Thread 1 1/16" Dia X 1 3/8"
<b>PX</b>	 1/2" PEX Tube Fitting 15/16" Dia X 1 1/8"
<b>PX3</b>	 3/4" PEX Tube Fitting 15/16" Dia X 1 1/8"
<b>W</b>	 1/2" Wirsbo® Tube Fitting 15/16" Dia X 1 1/2"
<b>W3</b>	 3/4" Wirsbo® Tube Fitting 1 1/8" Dia X 1 3/4"
<b>R</b>	 1/2" Rehau® Tube Fitting 15/16" Dia X 1 3/4"
<b>CM</b>	 <b>COMBINATION</b> 1/2" Compression Fitting 1/2" Copper Sweat Fitting 15/16" Dia X 1 1/4"

Model 22 & V22	
Dia. X Min. Length Req'd. In Heated Area	
<b>C</b>	 <b>COMBINATION</b> Copper Sweat Fitting 1/2" K, L or M Inside 3/4" M Only Outside 15/16" Dia X 1 5/8"
<b>CP</b>	 <b>COMBINATION</b> 1/2" Male Pipe Thread 1/2" Female Sweat 15/16" Dia X 1 3/4"
<b>P</b>	 <b>COMBINATION</b> 1/2" Female Pipe Thread 3/4" Male Pipe Thread 1 1/16" Dia X 1 7/8"
<b>PX</b>	 1/2" PEX Tube Fitting 15/16" Dia X 1 3/4"
<b>PX3</b>	 3/4" PEX Tube Fitting 15/16" Dia X 1 3/4"
<b>W</b>	 1/2" Wirsbo® Tube Fitting 15/16" Dia X 1 1/2"
<b>W3</b>	 3/4" Wirsbo® Tube Fitting 1 1/8" Dia X 1 3/4"


**Rough-In Dimensions / O.A.L.**



**Model 14, 16, 17, 19**



**Model 22**



**Model V22**


**\*PRV Pressure Relief Valve**  
 U.S. Patent 6,532,986 B1

**Standard on Models 16, 19, 22 & V22**

**Upgrade the Model 14 & 17 with RK-PRV Rod Assembly**

The patented, resetting PRV prevents the faucet tube from bursting in freezing conditions even if a hose is unintentionally left on. The PRV protects up to 125 psi of backpressure and therefore does not require an add-on vacuum breaker.

**Piston activates at approx. 350 psi**



Inlet Connection

